

VERMONT DEPARTMENT OF HEALTH LABORATORY
195 COLCHESTER AVENUE
BURLINGTON, VERMONT 05402-1125
(802) 863-7335 (800) 660-9997 (VT ONLY)
WATER BACTERIOLOGY RESULTS

LITS Number 2008047167-001-A

State Health Dept No.10WB01254

Kit Type Kit AA Coliform (Regulated Systems)

WSID#

0000005096

Kit Number 9645416

Report To
MARC MAHEUX
JERICHO-UNDERHILL WATER
38 POKER HILL RD
PO BX 236
UNDERHILL VT 05489

Public Water System Only

JERICHO-UNDERHILL WATER

Sampler Title OPERATOR

Purpose of Sample Routine

Type of Sample Distribution

Chlorine, free 0.28

Chlorine, total

Field Temp (C)

Action Limit

Date/Time Received 08/03/2009 14:02:00

Date/Time of Collection 08/03/2009 13:30:00

Town Underhill

Collected By MARC MAHEUX

Sample Location 7 PARK ST DOWNSTAIRS SINK

Date Analyzed 08/04/2009

Field Sample Number

Report Status Final

Date Reported 08/04/2009

Released by VLD

Test	Code	Result Description
MMO-MUG	00	Total coliform not detected, E. coli not detected

Comments:

Registry Comments:

METHOD: SM9223

This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont Access to Public Documents law (1V.S.A.315-320) Results relate only to the items tested. This water was not analyzed for possible chemical contamination.

This reports shall not be reproduced, except in full, without the written approval of the laboratory.

If you have questions about this report, please call the laboratory at (802)863-7335

Date Printed: 08/04/2009 11:53:45